

## Memo

To: Sarah Leach, Deputy Clerk

**CC:** Jason Marr, Director of Public Works; Barb Wiens, Director of Planning and

Development; Derek Young, Manager of Engineering; Taylor Boyle, Engineering

Technologist; Lucas Smith, Engineering Technologist;

From: Gimuel Ledesma, Engineering Technologist

**Date:** October 19, 2022

**File No.:** B11/2022P

**RE:** Consent – 1053 Pelham Street Part 3

Town of Pelham Public Works Staff have reviewed the above noted application and supporting documentation to address the technical concerns regarding the submitted minor variance application. Application is made for consent to partial discharge of mortgage and consent to convey 607.6 square metres of land (Part 3), for future construction of a single detached dwelling. Part 1 is to be retained for continued residential use of the dwelling known municipally as 1053 Pelham Street.

This application is being considered concurrently with Consent Files B12/2022P and Minor Variance Files A15/2022P and A16/2022P.

## Public Works offer the following comments:

- Servicing plan for the lot will be required.
- Please be advised that no sideyard walkways that impede sideyard swale should be permitted
- Any future severance for part 1, entrance is permitted only on Pelham Street
- Street trees shall be planted in accordance with the Town's Tree Management Policy, S802-01

## Public Works offer the following conditions:

- That the applicant confirm that no existing utilities currently cross the proposed new
  property line. Should any services cross this new property line, the applicant will be
  responsible for costs associated with their relocation and/or removal.
- Town of Pelham Public Works Staff require that the applicant submit an overall lot grading and drainage plan to demonstrate that the drainage does not negatively impact nor rely on neighboring properties.
- Tree preservation plan will be required (include trees on lot grading plan)
- Each lot shall be serviced individually



 The applicant obtains a Driveway Entrance and Culvert Permit from the Public Works department for the construction of all new or modification of existing driveways or entrances. Installation and/or modification of all entrances shall be completed in accordance with Town Standards.