

Engineering Department engineering@pelham.ca 905-892-2607 ext 332

# **Engineering Department Committee of Adjustment Report**

For

B11-2023P 1008 Haist Street

August 4, 2023



Engineering Department engineering@pelham.ca 905-892-2607 ext 332

Town staff have reviewed the following documentation for the purpose of **B11-2023P – 1008 Haist Street** Consent application for:

Application is made for consent to convey 91.0m square metres of land (Part 2), to be added to the abutting property to the north (Part 1-1022 Haist Street), for future construction of a detached accessory garage. Part 3 is to be retained for continued residential use of the dwelling known municipally as 1008 Haist Street.

The following information was submitted as part of the application for consideration:

 Proposed Severance Sketch for 1022 Haist Street by JD Barnes Ltd, dated June 28,2023

This full report contains following comments in conjunction with Minor Variance application A17-2023P – 1022 Haist Street.



Engineering Department engineering@pelham.ca 905-892-2607 ext 332

#### **Introduction:**

The properties are located on the southwest corner of Haist Street South and Welland Road. The two properties each contain a single detached dwelling fronting onto Haist Street. 1008 Haist Street contains a two-storey dwelling with an attached garage and is landscaped with mature vegetation with a large front yard setback, which is consistent with the established character of the surrounding neighbourhood. 1022 Haist Street has a bungalow that faces Haist Street with a single car driveway accessing Haist Street and a secondary driveway access on Welland Road. This property also contains lovely mature vegetation with an expansive front yard area. Outdoor amenity area for this dwelling is provided on the west side of the dwelling.

It is understood that the owner of the properties wishes to construct an attached accessory garage on the south side of the dwelling located at 1022 Haist Street. In orderto accommodate the proposed attached garage, a minor boundary adjustment between the two properties is required, together with an application for a minor variance to address two zoning deficiencies triggered by the proposal.

# **Analysis:**

Please see comment and conditions below.



Engineering Department engineering@pelham.ca 905-892-2607 ext 332

# **Public Works offer the following comment:**

 Please be advised that no sideyard walkways that impede sideyard swales shall be permitted

# **Public Works offer the following conditions:**

- Town staff will require a comprehensive lot grading and drainage plan demonstrating that storm water runoff will not negatively impact nor rely upon neighboring properties, to the satisfaction of the Director of Public Works or his designate.
- Confirm that no existing utilities cross the proposed lot lines. Should any services cross these lot lines, the applicant shall be responsible for costs associated with their relocation and / or removal.