

To: Sarah Leach

Cc: Andrew Edwards

From: Alex Foisey, Building Intake/Zoning Technician

Date: March 20th, 2024

Subject: Building Comments on Applications to the Committee of Adjustment for
1313 Victoria Avenue
File Number: A4-2024P

Comments:

The building department will require a permit be applied for as the tent is attached to the building.

The fire department also needs to be informed if any tent is larger than 30m², proposed tent is 37.16m²

Building has no comments on the proposed food Truck

Respectfully,
Alex Foisey